

CASCADE UNION ELEMENTARY SCHOOL DISTRICT

Bid No. CUESD-CUPCCAA-2023-09-29

REQUEST FOR PROPOSAL

Low Voltage Wiring and Audio/Visual System for Meadow Lane Elementary New Gymnasium

Addendum No. 01

Date: 2023/10/04

FOR THE ABOVE-MENTIONED REQUEST FOR PROPOSAL AND TO ALL PROSPECTIVE BIDDERS, THIS ADDENDUM IS ISSUED AS A RESPONSE TO THE REQUESTS FOR INFORMATION, FOR AREAS IN THE ORIGINAL DOCUMENT THAT REQUIRED FURTHER CLARIFICATION, AND FOR A CHANGE IN THE SECOND SCHEDULED SITE-WALK DUE TO CONFLICTS WITH ONGOING CONSTRUCTION.

REVISIONS:

FOR SITE-WALKS SECTION:

- Due to ongoing construction projects and efforts, there is a need to reschedule the second site-walk which was originally planned for 10:00am Tuesday, October 10th. There will be two new times/dates: 10:00am Friday, October 05th, and 10:00am Thursday, October 12th. If a vendor was planning to attend the original second site-walk and is unable to adjust scheduling to one of these two alternative days/times then please reach out to Chad Johnson, IT Director, at chad.johnson@cuesd.com to attempt to coordinate another meeting. *(Note that there haven't been any changes to the first site-walk and it will continue as planned at 2:00pm Thursday, October 10th.)*

FOR LOW VOLTAGE PORTION OF PROJECT:

- "Commscope CAT6 cabling" should read "Commscope CAT6 cabling, jacks and related accessories." The brands of cabling, jacks and accessories should match and also have quality/grade equivalence.
- "Commscope indoor/outdoor grade 12 strand fiber optic cabling" should read "Commscope indoor/outdoor grade 12 strand fiber optic cabling, connectors, and related accessories." The brands of cabling, connectors and accessories should match and also have quality/grade equivalence.

FOR AUDIO/VISUAL SYSTEM PORTION OF PROJECT:

- "Commscope CAT6 cabling" should read "Commscope CAT6 cabling, jacks and related accessories." The brands of cabling, jacks and accessories should match and also have quality/grade equivalence.

REQUEST FOR INFORMATION:

Q: The RFP calls for Commscope cabling, will other manufacturers such as Belden, Panduit, or Leviton be accepted if the cable proposed reaches the same quality standards?

A: In general, the brands Belden, Panduit, and Leviton are completely acceptable alternatives to Commscope for CAT6 cabling, jacks, connectors, and related accessories (NOTE: see *REVISIONS* above). Please see requirements in **Equivalent or Superior Products* of the RFP, particularly where the specifications of all substitutions must be provided before approval can be given.